

# EMC Certificate

Reference No.: *EMC/T02/98*  
Test Report : *ET86S-12-078*  
Date : *Jan. 13, 1998*

Applicant: *Chung Mei Fire Fighting Supplier Co., Ltd.*  
*82, Jen I Street, Wu Jih, Taichung Hsien,*  
*Taiwan, R.O.C.*

Manufacturer: *Chung Mei Fire Fighting Supplier Co., Ltd.*  
*82, Jen I Street, Wu Jih, Taichung Hsien,*  
*Taiwan, R.O.C.*

EUT: *Photo Electric Type Smoke Detector*

Trade mark:

Type(s): *CM-WT30L*

Serial No: ---

Rated power: *1.44mW*

Rated voltage: Input: *DC 24V (Monitor)* Output: *0-10V (Alarm)*

Rated current: *60 uA (Monitor Max.) 100 mA (Alarm Max.)*

Relative humidity: *57%*

Temp.: *23 C*

Standard(s): *EN 55014* *EN 55104*  
*EN 61000-4-2*  
*EN 61000-4-4*  
*ENV 50141*

*The equipment under test fulfils the requirements of the standards above*



-----  
Kimmo Ahtokari, Supervisor